



ADDENDUM NO.1
CITY OF ROCHESTER, NEW HAMPSHIRE
BID #07-09

Replacement of Carbon Filter Media

This addendum amends and/or supplements the bid documents as indicated below. Only these items alter the Bid Documents.

CLARIFICATION AS FOLLOWS: The following criteria are to replace criteria specified on page 6 and 7 of the bid documents.

CORRECTED CRITERIA

The media shall meet the following criteria:

<u>Test</u>	<u>Specifications</u>	
	<u>Minimum</u>	<u>Maximum</u>
Iodine Number., mg/g	900	
Moisture, wt%, as packed		2
Abrasion No	86	
A.D. g/cc	.53	
Effective size, mm	.08	1.0
Uniformity coefficient		2.1
Ash, Wt %		8
Trace Capacity Number	12	
Hardness Number	90	
Contact ph	7	
Volume Iodine, mg/vol%	475	
US Sieve Series		
>8US Mesh		15
<30US Mesh		4