

ADDENDUM NO. 3

CITY OF ROCHESTER, NEW HAMPSHIRE

BID #10-31-Rochester Community Center Interior Renovations

This addendum amends and/or supplements the bid documents as indicated below. Only these items alter the Bid Documents.

This addendum may also be obtained from City of Rochester's web site:
www.rochesternh.net or will be available by request via e-mail at the following address:
purchasing@rochesternh.net

Addendum is also available by written requests addressed as follows:

CLARIFICATIONS AS FOLLOWS:

1. Per Addendum # 2, item 7, "Bid Security", What percentage of the total cost do you want us to carry? *5%*
2. Are there any interior room signs that will be required with this project?
Bathroom, office, meeting room etc. *Accessible signage will be required per IBC 2006 section 1110.*
3. Please advise if there is a specific Bid Bond form to use or if it is acceptable to just use the AIA Bond Form? *AIA Bond Form is fine*
4. Will there the list of all Attendees that were at the walk thru made public? *The list is available upon request from the Purchasing office.*
5. In addendum # 2 Revised Outline Specifications, General Conditions, item 6
It states that there are 2 locations that asbestos was identified. While walking the room, I counted three areas with the same style VCT. Can you confirm that there are only 2 affected areas?
 - Area 1 is located around the column that will be located in room 102 (approx 144 sq ft)
 - Area 2 is located in the area that will become Corridor 125 (approx 72 sq ft)
 - Area 3 is located in the area that will become room 114 (approx 60 sq ft)
Looks like the VCT runs under the wall into the next room? *Assume that it is for bidding purposes.*
6. Do you want cat 5E or cat 6 cable for the data and phone cabling? *Cat 5E*
7. Does the data, phone and cable T.V. cable need to be plenum rated? *yes*
8. In what room will the data, phone and cable T.V. cabling terminate (where is the head end equipment)? *Existing HVAC room on north side of building.*
9. Will we need to provide any head end equipment for the data, phone, and cable T.V. cabling? *No*

10. Do you require stainless steel or nylon cover plates for receptacles and switches?
Nylon is fine