ADDENDUM NO. 1

CITY OF ROCHESTER, NEW HAMPSHIRE

BID #10-37-RFD Fire Sprinkler System

This addendum amends and/or supplements the bid documents as indicated below. Only these items alter the Bid Documents.

This addendum may also be obtained from City of Rochester's web site: www.rochesternh.net or will be available by request via e-mail at the following address: purchasing@rochesternh.net

Addendum is also available by written requests addressed as follows:

Bid # 10-37 #1 Request City of Rochester, New Hampshire 31 Wakefield St. Rochester, NH 03867 Attn: Purchasing Agent

CLARIFICATIONS AS FOLLOWS:

- 1.) Under "Intent" *remove* item D. "All painting of exposed piping to be done by sprinkler contractor."
- 2...) *Add* Hydraulic specifications from street 70lbs static, 1190gpm/52lbs, Residual 68lbs.
- 3.) Under "Codes and Permits" modify item "C" to *remove* "and fees"
- 4.) *Add*: Please submit two prices in the final bid. One price shall include sprinkling the unheated space above the drop ceilings on the second floor. The other price will not include sprinkling the unheated space.

Please utilize revised Bid Proposal Form 2 for all bid submittals.

BID PROPOSAL FORM 2 Bid #10-37

VENDOR NA	ME:		
CONTACT PI	ERSON:		
ADDRESS:_			
TELEPHONE	E:FAX #:	E-MAIL	
SIGNATURE	: <u> </u>		
WARRANTY	INFORMATION MUST BE SU	JBMITTED WITH BID	
Item # 1	Cost of a Fire Sprinkler System, for the Rochester Fire Department		
	Central Station, including all associated parts and equipment. (exclude		
	second floor non-combustible space)		
	\$Bid amount in figures		
	\$Bid amount in words	<u> </u>	
Item # 2		, for the Rochester Fire Department	
	•	sociated parts and equipment. (include	
	second floor non-combustible space)		
	\$Bid amount in figures		
	Bid amount in figures		
	\$Bid amount in words	<u></u>	