

ADDENDUM NO 1

CITY OF ROCHESTER, NEW HAMPSHIRE

BID #10-39-Membrane Roofing at the Community Center

This addendum amends and/or supplements the bid documents as indicated below. Only these items alter the Bid Documents.

This addendum may also be obtained from City of Rochester's web site: www.rochesternh.net or will be available by request via e-mail at the following address: purchasing@rochesternh.net

Addendum is also available by written requests addressed as follows:

**Bid # 10-39 #1 Request
City of Rochester, New Hampshire
31 Wakefield St.
Rochester, NH 03867
Attn: Purchasing Agent**

CLARIFICATIONS AS FOLLOWS:

The following should be added to the bid specifications for Bid # 10-39 Membrane Roofing at the Community Center.

1. The project must be completed by September 1, 2010
2. The small bump out roof located on the middle roof section is not included in the scope of work for this project. This roof has an existing warranty from Firestone Building Projects Co. Install appropriate tie-in details according to manufacturer requirements to maintain warranty coverage.
3. Include re-wrapping the ductwork with like membrane for one unit on the upper roof and two units on the lower roof areas.
4. Remove 5 unused and capped curbs and 16 unused pipe supports. Supply new steel decking (min. 22 ga.) to match existing steel deck profile. Install and attach new deck in accordance with current industry standards at curb locations. Install min. 18 ga. steel plates to cover all pipe penetrations removed as necessary.
5. City will provide dumpsters and waste removal at no cost to Contractor.