Questions and answers pertaining to bid 11-18

- 1.) Make? ITT Federal
- 2.) Model? MD-15
- 3.) KW output rating? 150 KW
- 4.) Engine manufacturer? Cummins
- 5.) Type of fuel (Diesel, Gas, Natural Gas, Propane)? Diesel
- 6.) Fuel tanks included? No
- 7.) Hours of service? 338

8.) Year of install? Installed in 2003 as a used generator. The generator is 28 years old

- 9.) Is the unit sound attenuated (housing around the genset)? Yes
- 10.) Type of cooling system (Radiator/City Water) Radiator
- 11.) Is the transfer switched included? No