

**ADDENDUM NO. 1**

**CITY OF ROCHESTER, NEW HAMPSHIRE  
BID #17-35 Library Fire Panel Replacement**

This addendum amends and/or supplements the bid documents as indicated below. Only these items alter the Bid Documents.

This addendum may also be obtained from City of Rochester's web site: [www.rochesternh.net](http://www.rochesternh.net) or will be available by request via e-mail at the following address: [purchasing@rochesternh.net](mailto:purchasing@rochesternh.net)

Addendum is also available by written requests addressed as follows:

**Bid # 17-35 Library Fire Panel Replacement  
City of Rochester, New Hampshire  
31 Wakefield St.  
Rochester, NH 03867  
Attn: Purchasing Agent**

**CLARIFICATIONS AS FOLLOWS:**

1. **Bid Form Revision-** Under specifications for replacement of existing fire alarm panel it states that the existing horn/strobes will not be changed unless they are found to be incompatible to the new system.

This should be revised to say the existing 23 speaker strobes and 11 strobes will need to be changed. The strobes should be equal or equivalent to System Sensor P2R horns/strobes and SR strobes and compatible with the fire alarm panel being proposed by the bidder.

Please include all cost with above in the total lump sum of the bid.