

ADDENDUM NO. 2

CITY OF ROCHESTER, NEW HAMPSHIRE BID #19-03 City Council Chambers Broadcast and AV Upgrade

This addendum amends and/or supplements the bid documents as indicated below. Only these items alter the Bid Documents.

CLARIFICATIONS AS FOLLOWS: From Bid Site Visit: Tuesday July 3rd,

Question regarding IP based cameras

Bidders are required to provide a network diagram that includes all device to be provided as part of the project, connections to any current city devices or services, and any specific network configuration needed. The city will be providing switch, ports and management.

CLARIFICATIONS AS FOLLOWS: From Bid Site Visit: Tuesday July 3rd,

Question regarding conduit for exposed wiring

Desire for conduit for new cabling was discussed. In addition to appropriate covering of cables in Council Chambers, vender will give alternative cost option for conduit for cable run in basement and other areas as deemed feasible.